



Accredited by the Federal Ministry
for Labour and Economy of the Republic of Austria



ÖVGW Certificate

of the conferment of the right to use
the ÖVGW Quality Mark for Water

Registration number

W 1.626

Period of validity

until the end of February 2025

Owner ♦ Distribution in Austria

E. Hawle Armaturenwerke GmbH

Wagrainerstraße 13
4840 Vöcklabruck

Manufacturer

ÖZ-KAN Makina ELM. San. ve TIC. A.S. / TR

Type of test

Renewal test

Test report

2101585 / 17675 / 2K dated 31 August 2022

Quality standards / Testing directives

- QS-W 501/1 version December 2014
- ÖNORM EN 1074-1 Standard
version September 2000
- ÖNORM EN 1074-2 Standard
version September 2004

Product

Double offset-flanged butterfly valve

“Type 9881K”

for drinking-water supply

manually operated by handwheel for indoor use
above ground, or laid underground,

with the nominal diameters of
DN 150, 200, 250, 300, 350, 400, 450, 500, 600,
700, 800, 900, 1000, 1100 and DN 1200

in pressure levels PN 10 and PN 16

ZVR 818158001

The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products
“Conditions for the award of the ÖVGW Quality Mark for gas and water supply products”

Vienna, 5 September 2022

Dipl.-Ing. (FH) Alexander Schwanzer
Head of the ÖVGW Certification Office