



Österreichische Vereinigung für das Gas- und Wasserfach
A-1010 Wien, Schuberting 14
Telefon: +43 / 1 / 513 15 88-0* / Telefax: +43 / 1 / 513 15 88-25
E-Mail: office@ovgw.at / Internet: www.ovgw.at



Accredited by the Federal Ministry
of Science, Research and Commerce



ÖVGW Certificate

of the conferment of the right to use
the ÖVGW Quality Mark for Water

Registration number

W 1.150

Period of validity

until the end of October 2020

Owner ♦ Distribution in Austria

E. Hawle Armaturenwerke GmbH

Wagrainerstraße 13
4840 Vöcklabruck

Manufacturer

E. Hawle Armaturenwerke GmbH / AT

Type of test

Renewal test

Test report

TGM - VA HL 8522 dated 20 September 2017

Quality standards / Testing directives

- QS-W 501/1 version December 2014
in combination with EN 1074-1 und EN 1074-2
ÖNORM Standards

Product

House-connection slider for feeding the drinking
water supply system with cold water, PN 16

Types:

2600 DN 20, 25, 32, 40, 50

2800 DN 25, 32, 40, 50

2810 DN 20, 25, 32, 40 including ZAK 34

2810 DN 32, 40, 50 including ZAK 46

for PE-HD pipes

with the following registration features:

- for underground and shaft installations
- manually operated or motor operated

ZVR 818158001

The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products
"Conditions for the award of the ÖVGW Quality Mark for gas and water supply products."

Vienna, 17 October 2017

Dipl.-Ing. (FH) Alexander Schwanzer
Head of the ÖVGW Certification Office