



Österreichische Vereinigung für das Gas- und Wasserfach  
A-1010 Wien, Schuberting 14  
Telefon: +43 / 1 / 513 15 88-0\* / Telefax: +43 / 1 / 513 15 88-25  
E-Mail: office@ovgw.at / Internet: www.ovgw.at



Accredited by the Federal Ministry  
for Digital, Business and Enterprise of the Republic of Austria



## ÖVGW Certificate

of the conferment of the right to use  
the ÖVGW Quality Mark for Water

Registration number

**W 1.363**

Period of validity

**until the end of May 2023**

Owner ♦ Distribution in Austria

**E. Hawle Armaturenwerke GmbH**  
Wagrainerstraße 13  
4840 Vöcklabruck

Manufacturer

E. Hawle Armaturenwerke GmbH / AT

Type of test

Renewal test

Test report

TGM – VA HL 8780

Quality standards / Testing directives

• QS-W 300 (version January 2019), Annex K.5

Product

Water Meter Assembly Sets

Type: 2930, DN 40

2931, DN 25, DN 32

2932, DN 25

2960, DN 50

Maximum operating pressure: 10 bar

Operating temperature up to 30 °C

Component parts included within the scope of  
registration:

- Mounting bracket according to ÖNORM B  
2534 Standard:

Order No.	DN	Slider connection
2930	40	2 internal threads G ½" ISO 228
2931	25	2 internal threads G 1" ISO 228
	32	2 external threads R 1 ¼" EN 10226
2932	25	1 ZAK 34 socket connection, 1 internal thread G 1" ISO 228
2960	50	2 internal threads G 2" ISO 228

- Mounting bracket made of casting material,  
coated
- Shut-off valves made of brass (straight-pattern  
shut-off valves)

with integrated backflow preventer.

The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products  
"Conditions for the award of the ÖVGW Quality Mark for gas and water supply products."

Dipl.-Ing. (FH) Alexander Schwanzer  
Head of the ÖVGW Certification Office

Vienna, 29 April 2020