



Österreichische Vereinigung für das Gas- und Wasserfach
A-1010 Wien, Schuberting 14
Telefon: +43 / 1 / 513 15 88-0* / Telefax: +43 / 1 / 513 15 88-25
E-Mail: office@ovgw.at / Internet: www.ovgw.at



Accredited by the Federal Ministry
of Science, Research and Commerce

ÖVGW Certificate

of the conferment of the right to use
the ÖVGW Quality Mark for Gas

Registration number

G 1.475

Period of validity

until the end of June 2019

Owner ♦ Distribution in Austria

E. Hawle Armaturenwerke GmbH
Wagrainerstraße 13
4840 Vöcklabruck

Manufacturer

E. Hawle Armaturenwerke GmbH / AT

Type of test

Renewal test

Test report

TGM - VA HL 8411 dated 31 August 2016

Quality standards / Testing directives

- QS-G 100 version December 2014
- PG 437 version January 2008

Product

Metal fittings for gas distribution systems with
permissible operating pressures ≤ 16 bar

– GATE VALVE –

I_{2H} Category

Types:

- 4005 DN 25, 32, 40, MOP 5 bar
- 4005 E2 DN 50, 65, 80, 100, 125, 150, 200,
250, 300, 350, 400, MOP 16 bar
- 4705 E2 DN 50, 65, 80, 100, 125, 150, 200,
300, 500, MOP 16 bar

and with butt weld ends made of PE 100

Types:

- 4055 DN/dn 25/32, 32/40, 40/50,
MOP 10 bar
- 4055 E2 DN/dn 50/63, 65/75, 80/90, 100/110,
100/125, 150/160, 150/180, 200/200,
200/225, MOP 10 bar
- 4056 E2 DN/dn 80/90, 100/110, 100/125,
150/160, 150/180, 200/200, 200/225,
MOP 6 bar
- 4095 E2 DN/dn 50/63, 65/75, 80/90, 100/110,
100/125, 125/140, 150/160, 150/180,
200/200, 200/225, MOP 10 bar
- 4096 E2 DN/dn 80/90, 100/110, 100/125,
125/140, 150/160, 150/180, 200/200,
200/225, MOP 6 bar

ZVR 818156001

The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products
"Conditions for the award of the ÖVGW Quality Mark for gas and water supply products."

Vienna, 11 October 2016


Dipl.-Ing (FH) Alexander Schwanzer
Head of the ÖVGW Certification Office