



Österreichische Vereinigung für das Gas- und Wasserfach  
A-1010 Wien, Schuberttring 14  
Telefon: +43 / 1 / 513 15 88-0\* / Telefax: +43 / 1 / 513 15 88-25  
E-Mail: office@ovgw.at / Internet: www.ovgw.at



Accredited by the Federal Ministry  
of Science, Research and Commerce



## ÖVGW Certificate

of the conferment of the right to use  
the ÖVGW Quality Mark for Gas

Registration number

**G 2.219**

Period of validity

**until the end of March 2020**

Owner ♦ Distribution in Austria

**E. Hawle Armaturenwerke GmbH**  
Wagrainerstraße 13  
4840 Vöcklabruck

Manufacturer

E. Hawle Armaturenwerke GmbH / AT

Type of test

Renewal test

Test report

TGM – VA KU 26583 dated 22 May 2017

Quality standards / Testing directives

• PG 493 version April 2011

Product

Plastic isolation valve for gas pipelines  
POM gate valve

Type 2675

with pipe ends SDR 11 made of PE 100,  
MOP 10 bar

in dimensions DN/d<sub>n</sub>  
1"/32; 1½"/50 and 2"/63

ZVR 818158001

The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products  
"Conditions for the award of the ÖVGW Quality Mark for gas and water supply products."

Vienna, 12 June 2017

  
Dipl.-Ing. (FH) Alexander Schwanzer  
Head of the ÖVGW Certification Office