



Österreichische Vereinigung für das Gas- und Wasserfach
A-1010 Wien, Schubertfing 14
Telefon: +43 / 1 / 513 15 88-0* / Telefax: +43 / 1 / 513 15 88-25
E-Mail: office@ovgw.at / Internet: www.ovgw.at



Accredited by the Federal Ministry
for Digital, Business and Enterprise of the Republic of Austria



ÖVGW Certificate

of the conferment of the right to use
the ÖVGW Quality Mark for Water

Registration number

W 1.165

Period of validity

until the end of April 2021

Owner ♦ Distribution in Austria

E. Hawle Armaturenwerke GmbH
Wagrainerstraße 13
4840 Vöcklabruck

Manufacturer

E. Hawle Armaturenwerke GmbH / AT

Type of test

Supplementary test

Reason for supplement

New type 4340 E3

Test report

TGM – VA HL 8592 dated 9 June 2018

Quality standards / Testing directives

- QS-W 501/1 version December 2014
in combination with ÖNORM Standards
EN 1074-1 and 1074-2

Product

Combi – T

Flange T-piece
with integrated gate valve
(soft-sealing wedge gate valve)

for feeding the drinking water supply system
with cold water, PN16

Type: 4340 E2
DN 80-80, 100-65, 100-80, 100-100,
125-80, 125-100, 150-65, 150-80,
150-100, 150-150, 200-80, 200-100,
200-150, 200-200
(14 versions)

4340 E3
DN 80-80, 100-65, 100-80, 100-100,
125-80, 125-100, 150-65, 150-80,
150-100, 150-150, 200-80, 200-100,
200-150, 200-200
(14 versions)

with the following registration features:

- for underground and shaft installation
- manually or motor-operated

20The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products
"Conditions for the award of the ÖVGW Quality Mark for gas and water supply products."

Vienna, 20 June 2018

Dipl.-Ing (FH) Alexander Schwanzer
Head of the ÖVGW Certification Office