



Österreichische Vereinigung für das Gas- und Wasserfach
A-1010 Wien, Schuberttring 14
Telefon: +43 / 1 / 513 15 88-0* / Telefax: +43 / 1 / 513 15 88-25
E-Mail: office@ovgw.at / Internet: www.ovgw.at



Accredited by the Federal Ministry
for Digital, Business and Enterprise of the Republic of Austria



ÖVGW Certificate

of the conferment of the right to use
the ÖVGW Quality Mark for Water

Registration number

W 1.606

Product

Hawle Combiflex

Period of validity

until the end of September 2021

Combined structure with gate valves consisting
of a selection of one to four outlets for feeding
the drinking water supply system with cold water

Owner ♦ Distribution in Austria

E. Hawle Armaturenwerke GmbH
Wagrainerstraße 13
4840 Vöcklabruck

PN 10/PN 16

Types:

4420 E2 DN 100, 150, 200, 250, 300 (400)

4420 E3 DN 100, 150, 200

Manufacturer

E. Hawle Armaturenwerke GmbH / AT

with the following registration features:

- for underground and shaft installation
- manually or motor-operated

Type of test

Renewal and supplementary test

Reason for supplement

New type 4420 E3 available in the following
dimensions: DN 100, 150 and 200

Test report

TGM - VA HL 8625 dated 11 October 2018

Quality standards / Testing directives

- QS-W 501/1 version December 2014
in combination with ÖNORM Standards
EN 1074-1 and EN 1074-2

The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products
"Conditions for the award of the ÖVGW Quality Mark for gas and water supply products."

Vienna, 23 October 2018


Dipl.-Ing. (FH) Alexander Schwanzer
Head of the ÖVGW Certification Office